



Product Service

CERTIFICATE

No. Z1A 015912 0054 Rev. 00

Holder of Certificate: **Ebara Pumps Europe S.p.A.**

Via Campo Sportivo 30
38023 Cles (TN)
ITALY

Certification Mark:



Product: **Submersible electrical pumps**

Tested according to: EN IEC 60335-2-41:2021/A11:2021
EN 60335-1:2012/A15:2021
EN 62233:2008
AfPS GS 2019:01 PAK

With this certificate, in its capacity as a notified GS body, TÜV SÜD Product Service GmbH issues the GS Mark to the named certificate holder for the declared product with the named model designation in accordance with section 20 ProdSG (German Product Safety Act). The product meets the safety and health requirements of section 20 (3) ProdSG. The manufacturer is reminded of their obligations in accordance with section 24 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition, the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: ELS2117115A

Valid until: 2028-06-25

Date, 2023-06-26

(Massimo Mendo)



CERTIFICATE

No. Z1A 015912 0054 Rev. 00

Model(s): OPTIMA MA NRV H07RN8-F TSGS - code:1751104600
 OPTIMA M NRV H07RN8-F TSGS - code: 1751004600
 OPTIMA MS H07RN8-F TSGS - code: 1752104600

Brand Name: EBARA

Rated input voltage: 230-240 VAC
 Rated frequency: 50 Hz
 Rated power: 0.43 kW
 Rated current: 1.9 A
 Maximum rated temperature: 50 °C
 Maximum submersion depth: 5 m
 2 m (solo Optima MS)
 Protection class: I
 Degree of protection: IP68